



PARSONS HALL INDUSTRIAL ESTATE
HIGH STREET
IRCHESTER
NORTHANTS
NN29 7AB

TEL: 01933 410066
FAX: 01933 410077

Oxford Swim

Our ref: 3722SB

SYSTEM STATUS

For the attention of: Darrin Roles

High:	✓
-------	---

Satisfactory:	N/A
---------------	-----

Failed:	N/A
---------	-----

NATURAL BATHING WATERS RESULTS

Location : OXFORD SWIM

Date sampled: 24/08/15

Sample Point	Total Coliforms cfu/100ml	E Coli cfu/100ml	Faecal Streptococci cfu/100ml	TVC cfu/100ml
RIVER THAMES WATER	353	53	50	715

The following is taken from the Environment Agency Guidance for Natural Bathing Water Quality

Water Quality is 'High'

Total Coliforms <500cfu/100 ml

Faecal Coliform/E Coli <100 cfu/100ml

Faecal Streptococci/Intestinal Enterococci <100 cfu/100ml

Water Quality is 'Satisfactory'

Total Coliforms <10,000cfu/100 ml

Faecal Coliform/E Coli <2,000 cfu/100ml

Faecal Streptococci/Intestinal Enterococci <100 cfu/100ml

Water Quality is assessed as 'Failed'

Total Coliforms >10,000cfu/100 ml

Faecal Coliform/E Coli >2,000 cfu/100ml

Faecal Streptococci/Intestinal Enterococci >100 cfu/100ml